

Date: 2/3/2025

Addendum #2

Project: Kitchen & Cafeteria Renovation at North Providence High School

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Clarifications:

- Change Circular light fixture to: Day-O-Lite COML-44D. To have 8' diameter, Surface mount to ACT grid, color – white. New fixtures to be connected to existing circuits and controls. Contractor to determine existing circuiting and switching in the field. Abandoned circuits to be removed back to source panel.
- 2. New wood doors to have a stain finish color and sheen from manufacturers standard options.

END